



ਦਫਤਰ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਪ੍ਰਾਂਤਕ ਉਪ ਮੰਡਲ ਭ ਤੇ ਮ ਸ਼ਾਖਾ, ਸੰਗਰੂਰ
ਦੂਜੀ ਮੰਜਿਲ ਬਲਾਕ-2, ਜਿਲ੍ਹਾ ਪ੍ਰਬੰਧਕੀ ਕੰਪਲੈਕਸ ਸੰਗਰੂਰ।

ਟੈਲੀਫੋਨ/ਫੈਕਸ ਨੰਬਰ. 01672-234114

EMAIL:-sdeprovincialsangrur@gmail.com



ਵੱਲ

ਪ੍ਰਿੰਸੀਪਲ,
ਬਾਬਾ ਸ਼ਹੀਦ ਸਿੰਘ ਪਬਲਿਕ ਸਕੂਲ,
ਬਾਲੀਆ (ਸੰਗਰੂਰ)।

ਨੰ: 103

ਮਿਤੀ:- 08/05/2026

ਵਿਸ਼ਾ: ਸਾਲ 2026-27 ਦੇ ਲਈ ਬਿਲਡਿੰਗ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕਰਨ ਸਬੰਧੀ।

ਹਵਾਲਾ:- ਆਪ ਦਾ ਪੱਤਰ ਨੰ. ਨਿੱਲ ਮਿਤੀ 21.04.2026 ਵੱਲ ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ, ਪ੍ਰਾਂਤਕ ਮੰਡਲ, ਲੋਕ ਨਿਰਮਾਣ ਵਿਭਾਗ ਭ ਤੇ ਮ ਸ਼ਾਖਾ, ਸੰਗਰੂਰ।

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਸਬੰਧੀ ਹਵਾਲਾ ਅਧੀਨ ਪੱਤਰ ਰਾਹੀਂ ਆਪ ਵੱਲੋਂ ਸਾਲ 2026-27 ਲਈ ਸਕੂਲ ਬਿਲਡਿੰਗ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕਰਨ ਦੀ ਮੰਗ ਕੀਤੀ ਗਈ ਹੈ। ਜਿਸ ਦੇ ਸਬੰਧ ਵਿੱਚ ਪ੍ਰਾਪਤ ਹੋਏ ਕੇਸ ਅਨੁਸਾਰ ਲੋੜੀਂਦੀ ਇੰਸਪੈਕਸ਼ਨ ਕੀਤੀ ਗਈ ਅਤੇ ਇੰਸਪੈਕਸ਼ਨ ਕਰਨ ਉਪਰੰਤ ਬਿਲਡਿੰਗ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਆਪ ਨੂੰ ਅਗਲੇਰੀ ਯੋਗ ਕਾਰਵਾਈ ਹਿੱਤ ਭੇਜਿਆ ਜਾਂਦਾ ਹੈ। ਲੋੜੀਂਦੀ ਇੰਸਪੈਕਸ਼ਨ ਫੀਸ ਬਾਬਤ ਰੁਪਏ 10,000/- ਈ-ਚਲਾਨ ਨੰ. 23280026 ਰਾਹੀਂ ਆਪ ਦੁਆਰਾ ਡੀ.ਡੀ.ਓ. ਕੋਡ 0604 ਹੈੱਡ 8782-00-102-01-00 ਵਿੱਚ ਜਮ੍ਹਾਂ ਕਰਵਾ ਦਿੱਤੀ ਗਈ ਹੈ।

ਨੱਥੀ/ਸਰਟੀਫਿਕੇਟ

ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ
ਪ੍ਰਾਂਤਕ ਉਪ ਮੰਡਲ, ਲੋ.ਨਿ.ਵਿ
ਭ ਤੇ ਮ ਸ਼ਾਖਾ, ਸੰਗਰੂਰ।

ਪਿੱਠ ਅੰਕਣ ਨੰ.

ਮਿਤੀ:-

ਉਪਰੋਕਤ ਦਾ ਉਤਾਰਾ ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ, ਪ੍ਰਾਂਤਕ ਮੰਡਲ, ਲੋਕ ਨਿਰਮਾਣ ਵਿਭਾਗ ਭ ਤੇ ਮ ਸ਼ਾਖਾ, ਸੰਗਰੂਰ ਨੂੰ ਉਨ੍ਹਾਂ ਦੇ ਪਿੱਠ ਅੰਕਣ ਨੰ. 945 ਮਿਤੀ 24-04-2026 ਦੇ ਸਬੰਧ ਵਿੱਚ ਸੂਚਨਾ ਹਿੱਤ ਭੇਜਿਆ ਜਾਂਦਾ ਹੈ ਜੀ।

ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ
ਪ੍ਰਾਂਤਕ ਉਪ ਮੰਡਲ, ਲੋ.ਨਿ.ਵਿ
ਭ ਤੇ ਮ ਸ਼ਾਖਾ, ਸੰਗਰੂਰ।

Mr. Pervinder Kaur (Principal)
Baba Shaheed Singh
Public Sr. Sec. School,
Balian, Sangrur (20677)
Affiliation No. 1630696




Building Safety Report

Name of School :- Baba Shaheed Singh Public School, Balian (Sangrur)


I have visited the above-mentioned school Building along with Sh. Rishav Dev, Junior Engineer and on his visually inspection, it seems visually safe subject to the following observations and conditions:-

- a) Parameters to check the stability and safety of building as Architectural Drawings, Bearing capacity, Foundation detail, Structural Drawings, Technical Specifications, Test Reports of Material used, Quality Control reports and certificate from the Engineer in-Charge for construction are not available.
- b) In case any addition, alteration or expansion and modification to this building are done certificate may be obtained after the completion from the undersigned.
- c) In case the building is affected by flood or if there is any settlement of walls/ foundation or sagging of roofs etc. immediate inspection of the undersigned be arranged to check stability and safety of the building.
- d) A separate certificate regarding Fire Fighting should be obtained from the competent Authority.
- e) A separate certificate regarding Electrical works should be obtained from the competent Authority.
- f) The owner of the building / Management is fully responsible regarding safety of the building from all angles in spite of the report.
- g) The covered area of the building as per Drawings is 23867.50 Sq.ft
- h) The report is not valid for legal purpose.
- i) The building seems visually safe to occupy for normal use to **One Year, upto 31/03/2027**
- j) This Building Safety Certificate should not be considered as NOC for Road Access which will be taken separately by the School as per Government Policy No. 5/13/018-3BR3/1294287/3 Dated: 10.08.2018.


Junior Engineer

Dr. Pervinder Kaur (Principal)
Baba Shaheed Singh
Public Sr. Sec. School,
Balian, Sangrur (20677)
Phone No. 1630696




Sub Divisional Engineer
Provincial Sub Division
PWD B&R, Sangrur