

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

No. 498

Date : 15 April / 2026

It is certified that an inspection team headed by Sh. Piyush Garg (J.E) from Water Supply and Sanitation Sub Division No.1 Sangrur inspected the Baba Shaheed Singh Public School, Distt. Sangrur on 25-03-2026 and Based on the test reports of water samples dated 07.04.26, & 15.04.26, Aluminium in the RO Water is Above the Acceptable Limit but Below the Permissible Limit. It was found that the Baba Shaheed Singh Public School, Distt. Sangrur has safe RO drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period from **15-04-2026 to 31-03-2027**

NOTE:- It Is Strictly Advised to do Quarterly testing and if Aluminium goes above Permissible Limit take immediate Preventive Measures.

Signature with Seal :

Name : Sh. Deepesh Goyal

Designation : Sub Division Engineer.

To

The Principal

Baba Shaheed Singh Public School,