

**REGIONAL WATER TESTING LAB, SANGRUR**  
Prem Basti, D. C Office Road, Opposite to Punjab Gramin Bank, Sangrur  
rwtlsangrur@gmail.com

To,

Sant Ishar Singh Public School Chhahar  
Chhahar


No.: RWTL/SNG/2425/00672 Dated : 18/07/2024

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. SISPS/4629 Dated: 09/07/2024

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 11/07/2024. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Sangrur

D/A : Test Report



**Authorized Signatory**  
**For, Regional Water Testing Lab**  
**Sangrur**

**REGIONAL WATER TESTING LAB, SANGRUR**  
Prem Basti, D. C Office Road, Opposite to Punjab Gramin Bank, Sangrur  
rwtlsangrur@gmail.com

TEST REPORT						
Name & Address of Customer : <b>Sant Ishar Singh Public School Chhahar Chhahar</b>			Customer Reference No.		No : SISPS/4629 Dated : 09/07/2024	
			Sample Submitted by		Sushil Kumar	
			Date of Sample Receipt		11/07/2024	
			Analysis Starting Date		11/07/2024	
			Analysis completion Date		12/07/2024	
Discipline : <b>Chemical Testing, Bacteriological Testing</b>			Group: <b>Water</b>			
ULR No.:				Sample Type :		Treated Water
Test Report No.:		RWTL/SNG/2425/00672		Date of Issue :		18/07/2024
Registration no.:		RWTL/SNG/REG2425/00882		Condition of Sample :		Unsealed
Collection Point:		Treatment Plant (RO/CWPP/ARP/HH Purifier)		Quantity/Type of Bottle:		1000 ml / Plastic Bottles
Scheme/Source:		Not Mentioned(Not Mentioned)		Location/Depth :		R.O / NA
Village :		Not Mentioned		Habitation :		Not Mentioned
Block:		Dirba		District :		Sangrur
Latitude :		Not Mentioned		Longitude:		Not Mentioned
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	Iron(Fe)	BDL	1.0	No Relaxation	mg/l	Spectrophotometric Method
2	Sulphate(SO4)	BDL	200	400	mg/l	Spectrophotometric Method
3	Fluoride(F)	BDL(0.05)	1.0	1.5	mg/l	APHA 4500 F-(23rd Ed. 2017)/IS-3025 (Part-60)
4	Nitrate(NO3)	BDL(0.5)	45	No Relaxation	mg/l	Spectrophotometric Method/ APHA 4500 NO3-(23rd Ed. 2017)
5	Total Coliform(TC)	ND	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method
6	E-Coli	ND	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



**Dr. Ramesh Jhorar**  
Quality Manager  
Authorized Signatory  
For, Regional Water Testing Lab  
Sangrur

----- End of the Test Report -----